

Government of Bihar
Public Health Division Madhubani
Water Quality Testing Report

District- Madhubani				Testing date - 12.03.2025										Sample Collected by : School Staff										Received Sample on date : 12.03.2025				
SL. No.	Block	Location of Source	Type of Source	Parameters tested										pH	Turbidity	Total hardness	Calcium	Magnesium	Chloride	Alkalinity	Iron	Nitrate	Sulphate	Fluoride	Arsenic	Total Coll.		
1	JAYNAGAR	Scottish International School, Jaynagar, Madhubani	Boring water		1	264	72.8	20	30	304	0.18	3.20	8	0.74	-	< 1.1												
Desirable Unit				6.5 - 8.5	1	200	75	30	250	200	0.3	45	200	1.00	0.01	-												
Maximum Permissible limit in absence of alternate source				NR	5 NTU	600	200	100	1000	600	1	NR	400	1.5	NR	-												

Memo No. - 897

Madhubani, Dated -

12.03.2025

Copy to Principal Scottish International School, Jaynagar, Madhubani, Bihar to inform regarding reference to his letter No. - SIS/35/2025

Dated :- 12/03/2025


Lab Assistant


Chemist



Executive Engineer
P.H. Division, Madhubani
EXECUTIVE ENGINEER
PH DIVISION
MADHUBANI BIHAR